



CERTIFICATE OF APPROVAL

No CAF 174

This is to certify that, in accordance with
 TS00 General Requirements for Certification of Fire Protection Products
 The undermentioned products of

**Designated CERTIFIRE Approved Door and Blank Manufacturers
 as Converted by**

ARBOR FOREST PRODUCTS LTD

**Barrow Road, New Holland, North Lincolnshire, DN19 7RR
 Tel: 01469 532300 Fax: 01469 531867**

Have been assessed against the requirements of the Technical Schedule(s)
 denoted below and are approved for use subject to the conditions
 appended hereto:

SCOPE OF APPROVAL

Approved for the manufacture of
 door frames for use with
 specified CERTIFIRE approved
 fire doors

TECHNICAL SCHEDULE

TS10 Fire Resisting Door
 Assemblies with non- Metallic
 Leaves

Signed and sealed for and on behalf of CERTIFIRE



Sir Ken Knight
 Chairman
 WCL Impartiality Committee



Paul Duggan
 Certification Manager
 Warrington Certification Ltd



Issued: 1st June 2016
 Reissued: 10th May 2016
 Valid to: 9th May 2021

Page 1 of 3



CERTIFICATE No CAF 174 ARBOR FOREST PRODUCTS LTD

1. This approval relates to the manufacture of doorframes for use with specified CERTIFIRE approved fire doors. Subject to the under mentioned conditions, the doors when fitted in the frame and with hardware and seals specified in the door leaf certificate are designed to meet the requirements as detailed in the relevant certificates.
2. The door frames shall be of the following specifications/references:

Fire Check Casings:

63 x 100 F/s 58 x 94
 63 x 115 F/s 58 x 108
 63 x 140 F/s 58 x 133
 63 x 150 F/s 58 x 144
 50 x 150 F/s 44 x 144
 50 x 100 F/s 44 x 95
 50 x 115 F/s 44 x 108
 50 x 140 F/s 44 x 133
 63 x 115 F/s 50 x 100

Fire Check Linings:

38 x 115 F/s 30 x 108
 38 x 140 F/s 30 x 133

The timber to be utilised is stated to be redwood or whitewood of nominal density 450 kg/m³, at nominal moisture content of 12%.

3. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section 2 of the Technical Standards (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.'
4. All frames shall be manufactured in accordance with the frame specification as defined in the door data sheet having regard to the maximum door leaf sizes and configurations permitted under the door certification.
5. Processing is conducted in accordance with Arbor Forest Products Ltd procedures.
6. The process is approved on the basis of production surveillance under ISO 9001: 2008.
7. The approval relates to on-going production.
8. Approved frames carry a label identified with Arbor Forest Products Ltd name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

CERTIFICATE No CAF 174
ARBOR FOREST PRODUCTS LTD

9. The certified doors for which the provision of doorframe kits is approved are as follows:

Manufacturer	Certificate Number	Timber Door Product
Premdor Crosby Ltd	195	FD30 Flush
	198	FD30 Moulded Skin Chipboard Core
	240	FD30 PremCORE
Jeld-Wen UK Ltd	160	FD30 Flush timber door assemblies
	271	FD30 timber door assemblies
	192	FD30 Timber Door Assemblies with Non (Tubeboard Construction)
Vicaima Ltd	218	(Standard Duty Core) Timber Door Assemblies
J B Kind Limited & Irmade	154	FD30 timber door assemblies
Norma Doors Technologies S.A.	292	FD30 timber door assemblies
Corinthian Industries	433	FD30 Panelled door assemblies

The scope of approval and field of application for the doors is contained in the above referenced certificates.